

# OPTIMIZATION OF ELECTRICAL ENERGY AT BATUTEGI DAM, LAMPUNG PROVINCE OF INDONESIA

**Anggara WWS**  
Department of Water Resources,  
Faculty of Engineering,  
Brawijaya University, Malang,  
INDONESIA

**Lily Montarchi**  
Department of Water Resources,  
Faculty of Engineering,  
Brawijaya University, Malang,  
INDONESIA  
lilymont2001@yahoo.com,

## ABSTRACT

*This paper studied optimization electrical energy. Site of study was at Batutegi Dam, Lampung Province of Indonesia. The methodology consisted of optimization energy using dynamic programming. Mathematically, dynamic programming was used to solve any kinds of non linear constraint and objective function. Results could be used as consideration of operating electrical power in this location.*

*Keywords:* electrical energy, dynamic programming

## INTRODUCTION

The issue of water resources estimation and use had long been of particular scientific importance, but now it acquired extremely acute social and political character (Shiklomadov et al., 2011). The issue was especially urgent in the context of considerable economics transformation and changed in river run off. This was due, on the other hand, to the increasing role of anthropogenic factors associated with water consumption by the population, industry, energy, and agriculture, and, on the other hand, to change to global and regional climate. Analysis of changes in the characteristics of water resources and their use with the consideration of possible economic trends in the country and climate conditions was used to forecast water use and water availability.

Droughts influenced the planning and design of water supply infrastructure and inflicted considerable economic and social damage worldwide. Their frequent and irregular occurrence had been a prime reason for the planning and construction of water resources infrastructure intended to increase the reliability of water supply in drought-prone areas. Compounding the task of water planning for drought abatement, present-day climate simulation capabilities did not permit reliable long-range forecasting (Loaiciga, 2005)

Watershed restoration efforts had sought to balance poverty alleviation against conservation, and local governance vs technical expertise. The potential for institutionalized mistakes in water planning by examining common guidelines for watershed managements were released by any government in the world. The daily lives of millions people in the world depended directly on functioning watersheds providing drinking water, irrigation, energy, groundwater recharge, and other usages. Mistakes in watershed prioritization and planning could have serious local ramifications. When such mistakes were institutionalized on a national scale, the results could be tragic (Bhalla et al., 2011).

## CONTEXT AND REVIEW OF LITERATURE

## **Hydro electrical power and energy**

Generated power of hydro electrical power was analysis using the formula as follow (Arismunandar and Kuwahara, 1991):

## Note

P = generated power (kW)

H = effective head (m)

$H_{\text{eff}}$  = electrical generated discharge ( $\text{m}^3/\text{s}$ )

$$E = P \times 24 \times n \quad \dots \dots \dots \quad (2)$$

## Note

E = energy (1Wh)

P = power (kW)

n = number of days in a period (hour)

## Weibull Method (Montarcih, 2010)

$$P(X_m) = \frac{m}{N+1} \quad \dots \dots \dots \quad (3)$$

## Note

P(Xm) = probability of design rainfall

$N$  = number of rainfall observed data.

m = rank of accident

**Dynamic Programming** (Soetopo and Montarcih, 2009)

Elements of dynamic programming was described as Figure 2




Figure 2 Elements of Dynamic Programming

Formulation of forward recursive:

$$f_n^*(S_n) = \text{opt} [r_n(S_n, d_n) O f_{n-1}^*(S_{n-1})] \quad \dots \quad (4)$$

dn

Formulation of backward recursive:

$$f_n^*(S_n) = \text{opt} [r_n(S_n, d_n) O f_{n+1}^*(S_{n+1})] \quad \dots \quad (5)$$

dn

## METHODS

Location of study was at Center Lampung Regency, Lampung Province of Indonesia.. Site of location was as Figure 1. The methodologies were conisted of 1) collection of data (discharge, electrical plant), 2) analysis of dependable discharge; 3) analysis of optimized electrical energy. Technical data of Batutegi Dam Was described as Table 1 below. Initial state of reservoir was as Table 2.




Figure 1 Site of Location Study

Table 1 Technical data of Batutegi Dam

No	Data of Batutegi reservoir	Volume	Unit
1	Area of still water	= 21	Km <sup>2</sup>
2	Flood water level	= + 281.5	m
3	Normal water level	= + 274	m
4	The lowest water level	= + 226	m
5	Bruto capacity of reservoir	= 6,900,E+08	m <sup>3</sup>
6	Minimum capacity of reservoir	= 9,000,E+07	m <sup>3</sup>
7	Effective capacity of reservoir	= 6,000,E+08	m <sup>3</sup>
8	Height of dam	= 120	m
9	Capacity of spillway	= 1,93	m <sup>3</sup> /s
10	Capacity of turbine	= 29,76	MW
11	Effective head	= 90	m

Table 2 Initial state of reservoir

0	(0% of effective reservoir)	90.000.000	$m^3$
1	(20% of effective reservoir)	192.000.000	$m^3$
2	(40% of effective reservoir)	294.000.000	$m^3$
3	(60% of effective reservoir)	396.000.000	$m^3$
4	(80% of effective reservoir)	498.000.000	$m^3$
5	(100% of effective reservoir)	600.000.000	$m^3$

## FINDINGS AND DISCUSSIONS

Inflow used in this analysis was dependable discharge. Dependable discharge with 80% of probability was described as Table 3 below.

Table 3 Dependable discharge with 80% of probability

Month	Q ( $m^3/s$ )
Jan	7,9925
Feb	12,2995
Mar	15,1035
Apr	12,7735
May	12,97
Jun	6,7205
Jul	4,671
Aug	7,2095
Sep	4,138
Oct	2,9715
Nov	3,757
Dec	5,6575

Stages of dynamic programming in this case were months of the year. The simulation was carried out every month from Januari to December as described as Table 4 to 15 below'

### Note for Table 4 to 15:

Tahap = stage

Saktif, Debit PLTA, Efisiensi, Energi = Saktive, hydropower discharge, efficiency, energy

Tamp awal = initial of reservoir, Tamp akhir = end of reservoir

Keputusan = decision

$m^3/dt = m^3/s$ , sumber: perhitungan = source: analysis

Januari = Jan, Februari = Feb, Maret = Mar, April = Apr, Mei = May, Juni = Jun, Juli = Jul, Agustus = Aug, September = Sep, Oktober = Oct, Nopember = Nov, desember = Dec

Table 4 Simulation of January

Tahap 1 (Januari)		Inflow = 7,99 m <sup>3</sup> /dtk																							
Sakitif, Debit PLTA, Efisiensi, Energi																									
Tamp.	Tamp. Awal	Tampungan Akhir																							
Awal	+ inflow	9000000			19200000			29400000			39600000			49800000		60000000									
6,000E+08	6,214E+08	5,31E+08	198,403	0,85	148743,99	4,29E+08	160,322	0,85	120193,6	3,27E+08	122,240	0,85	91643,187	2,25E+08	84,157	0,85	63092,784	1,23E+08	46,075	0,85	34542,38048	2,14E+07	7,993	0,85	5991,9773
Maksimum																									
Keputusan																									

Sumber: Hasil Perhitungan

Table 5 Simulation of February

Tahap 2 (Februari)		Inflow = 12,30 m <sup>3</sup> /dtk																								
Sakitif, Debit PLTA, Efisiensi, Energi																										
Tamp.	Tamp. Awal	Tampungan Akhir																								
Awal	+ inflow	9000000			19200000			29400000			39600000			49800000		60000000										
9,000E+07	1,229E+08	3,29E+07	13,617	0,85	158952,88	6,03E+07	125,128	0,85	149702,00	4,00E+08	100,102	0,85	100,000	3,00E+08	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	148743,99			
1,920E+08	2,249E+08	3,35E+08	55,780	0,85	162011,86	3,29E+07	13,617	0,85	10208,89															120193,59		
2,940E+08	3,269E+08	2,37E+08	97,943	0,85	165070,83	1,35E+08	55,780	0,85	41818,27	3,29E+07	13,617	0,85	10208,892												91643,19	
3,960E+08	4,289E+08	3,39E+08	140,105	0,85	168129,8	2,37E+08	97,943	0,85	73427,64	1,35E+08	55,780	0,85	41818,267	3,29E+07	13,617	0,85	10208,892	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	63092,78		
4,980E+08	5,309E+08	4,41E+08	182,288	0,85	171188,77	3,39E+08	140,105	0,85	105037	2,37E+08	97,943	0,85	73427,642	1,35E+08	55,780	0,85	41818,267	3,29E+07	13,617	0,85	10208,89249				34542,39	
6,000E+08	6,329E+08	5,43E+08	224,431	0,85	174247,74	4,41E+08	182,288	0,85	136646,4	3,39E+08	140,105	0,85	105037,02	2,37E+08	97,943	0,85	73427,642	1,35E+08	55,780	0,85	41818,26749	3,29E+07	13,617	0,85	10208,892	5991,98
Maksimum																										
Keputusan																										

Sumber: Hasil Perhitungan

Table 6 Simulation of March

Tahap 3 (Maret)		Inflow = 15,10 m <sup>3</sup> /dtk																							
Sakitif, Debit PLTA, Efisiensi, Energi																									
Tamp.	Tamp. Awal	Tampungan Akhir																							
Awal	+ inflow	9000000			19200000			29400000			39600000			49800000		60000000									
9,000E+07	1,305E+08	4,05E+07	15,104	0,85	185570,84	4,05E+07	129,95	0,85	7227,00	4,00E+08	100,102	0,85	100,000	3,00E+08	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	174247,74		
1,920E+08	2,325E+08	4,42E+08	53,186	0,85	176519,89	4,05E+07	15,104	0,85	11323,09	4,00E+08	100,102	0,85	100,000	3,00E+08	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	136646,39		
2,940E+08	3,345E+08	4,44E+08	91,268	0,85	173460,92	4,42E+08	53,186	0,85	39873,5	4,05E+07	15,104	0,85	11323,094	4,00E+08	100,102	0,85	100,000	3,00E+08	0,00	0,85	0,00E+00	0,00	0,85	105037,02	
3,960E+08	4,365E+08	4,46E+08	129,351	0,85	170401,95	4,44E+08	91,268	0,85	68423,9	4,42E+08	53,186	0,85	39873,497	4,05E+07	15,104	0,85	11323,094	4,00E+08	100,102	0,85	100,000	3,00E+08	0,00	0,85	73427,64
4,980E+08	5,385E+08	4,48E+08	167,433	0,85	167342,97	3,46E+08	129,351	0,85	96374,3	4,44E+08	91,268	0,85	68423,9	4,42E+08	53,186	0,85	39873,497	4,05E+07	15,104	0,85	11323,09395	4,00E+08	100,102	0,85	41818,27
6,000E+08	6,405E+08	5,50E+08	205,516	0,85	164284	4,48E+08	167,433	0,85	125524,7	3,46E+08	129,351	0,85	96374,304	4,44E+08	91,268	0,85	68423,9	4,42E+08	53,186	0,85	39873,49718	4,05E+07	15,104	0,85	11323,094
Maksimum																									
Keputusan																									

Table 7 Simulation of April

Tahap 4 (April)		Inflow =	12,77	$m^3/dtk$	Saktif.Debit PLTA, Efisiensi, Energi																					
Tamp.	Tamp. Awal	Tampungan Akhir																								
Awal	+ inflow	9000000		19200000			29400000			39600000			49800000			60000000										
9,000,E+07	1,231,E+08	3,31,E+07	12,774	0.85	195147,13	6,695,E+07	0,85	19925,5	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	1185570,84								
1,920,E+08	2,251,E+08	1,35,E+08	52,125	0.85	164603,08	3,31E+07	12,774	0.85	9576,293	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	125524,71							
2,940,E+08	3,271,E+08	2,37,E+08	91,477	0.85	165554,76	1,35E+08	52,125	0.85	39078,38	3,31E+07	12,774	0.85	9576,293	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	96974,30						
3,960,E+08	4,291,E+08	3,39,E+08	130,829	0.85	168506,44	2,37E+08	91,477	0.85	68580,46	1,35E+08	52,125	0.85	39078,376	3,31E+07	12,774	0.85	9576,293	0,00E+00	0,00	68423,90						
4,980,E+08	5,311,E+08	4,41,E+08	170,181	0.85	167458,12	3,39E+08	130,829	0.85	98082,54	2,37E+08	91,477	0.85	68580,46	1,35E+08	52,125	0.85	39078,376	3,31E+07	12,774	0.85	9576,293	3,31E+07	12,774	0.85	39873,50	
6,000,E+08	6,331,E+08	5,43,E+08	209,533	0.85	168409,8	4,41E+08	170,181	0.85	127584,6	3,39E+08	130,829	0.85	98082,54	2,37E+08	91,477	0.85	68580,46	1,35E+08	52,125	0.85	39078,376	2,31E+07	12,774	0.85	9576,293	11323,09
<b>Maksimum</b>		<b>195147,13</b>		<b>127584,6</b>			<b>39082,543</b>			<b>68580,46</b>			<b>39078,376</b>			<b>9576,293</b>										
<b>Keputusan</b>		<b>9,00E+07</b>		<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>										

Sumber: Hasil Perhitungan

Table 8 Simulation of May

Tahap 5 (Mei)		Inflow =	12,97	$m^3/dtk$	Saktif.Debit PLTA, Efisiensi, Energi																				
Tamp.	Tamp. Awal	Tampungan Akhir																							
Awal	+ inflow	9000000		19200000			29400000			39600000			49800000			60000000									
9,000,E+07	1,247,E+08	3,47,E+07	12,970	0.85	204870,74	6,729,E+07	0,85	8825,5	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	195147,13							
1,920,E+08	2,267,E+08	1,37,E+08	51,052	0.85	165858,64	3,47E+07	12,970	0.85	9723,609	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	127584,63						
2,940,E+08	3,287,E+08	2,39,E+08	89,135	0.85	164906,96	1,37E+08	51,052	0.85	38274,01	3,47E+07	12,970	0.85	9723,609	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	98082,54					
3,960,E+08	4,307,E+08	3,41,E+08	127,217	0.85	163955,28	2,39E+08	89,135	0.85	66824,42	1,37E+08	51,052	0.85	38274,012	3,47E+07	12,970	0.85	9723,609	0,00E+00	0,00	68580,46					
4,980,E+08	5,327,E+08	4,43,E+08	165,300	0.85	163003,6	3,41E+08	127,217	0.85	95374,82	2,39E+08	89,135	0.85	66824,415	1,37E+08	51,052	0.85	38274,012	3,47E+07	12,970	0.85	9723,609	3,31E+07	12,970	0.85	39078,38
6,000,E+08	6,347,E+08	5,45,E+08	203,382	0.85	162051,92	4,43E+08	165,300	0.85	123925,2	3,41E+08	127,217	0.85	95374,819	2,39E+08	89,135	0.85	66824,415	1,37E+08	51,052	0.85	38274,01223	0,00E+00	0,00	9723,609	
<b>Maksimum</b>		<b>204870,74</b>		<b>123925,2</b>			<b>95374,819</b>			<b>66824,415</b>			<b>38274,01223</b>			<b>9723,609</b>									
<b>Keputusan</b>		<b>9,00E+07</b>		<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>									

Sumber: Hasil Perhitungan

Table 9 Simulation of June

Tahap 6 (Juni)		Inflow =	6,72	$m^3/dtk$	Saktif.Debit PLTA, Efisiensi, Energi																	
Tamp.	Tamp. Awal	Tampungan Akhir																				
Awal	+ inflow	9000000		19200000			29400000			39600000			49800000			60000000						
9,000,E+07	1,074,E+08	1,74,E+07	6,721	0.85	209909,1	6,729,E+07	0,85	0,00E+00	0,00	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	204870,74				
1,920,E+08	2,094,E+08	1,95,E+08	46,072	0.85	159465,66	1,74E+07	6,721	0.85	5038,359	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	123925,22			
2,940,E+08	3,114,E+08	2,21,E+08	85,424	0.85	159417,34	1,19E+08	46,072	0.85	34540,44	1,74E+07	6,721	0.85	5038,359	0,00E+00	0,00	0,85	0,00E+00	0,00	0,85	95374,82		
3,960,E+08	4,134,E+08	3,23,E+08	124,776	0.85	160369,02	2,21E+08	85,424	0.85	64042,53	1,19E+08	46,072	0.85	34540,442	1,74E+07	6,721	0.85	5038,359	0,00E+00	0,00	66824,42		
4,980,E+08	5,154,E+08	4,25,E+08	164,128	0.85	161320,7	3,23E+08	124,776	0.85	93544,61	2,21E+08	85,424	0.85	64042,526	1,19E+08	46,072	0.85	34540,442	1,74E+07	6,721	0.85	5038,359	38274,01
6,000,E+08	6,174,E+08	5,27,E+08	203,460	0.85	162272,38	4,23E+08	164,128	0.85	123046,7	3,23E+08	124,776	0.85	93544,609	2,21E+08	85,424	0.85	64042,526	1,19E+08	46,072	0.85	34540,44218	5038,359
<b>Maksimum</b>		<b>209909,1</b>		<b>123046,7</b>			<b>93544,609</b>			<b>64042,526</b>			<b>34540,44218</b>			<b>5038,359</b>						
<b>Keputusan</b>		<b>9,00E+07</b>		<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>						

Sumber: Hasil Perhitungan

Table 10 Simulation of July

Tahap 7 (Juli)

$$\text{Inflow} = \quad \quad \quad 4,67 \quad \text{m}^3/\text{dt}$$

Saktit, Debit PLTA, Efisiensi, Energi																											
Tamp.	Tamp. Awal	Tampungan Akhir																									
Awal	+ inflow	9000000			19200000			29400000			39600000			49800000		60000000											
9.000E+07	1.025E+08	1.25E+07	4.671	0.85	213410.95	1.025E+07	0.00	1.025E+07	0.00	1.025E+07	0.00	1.025E+07	0.00	1.025E+07	0.00	1.025E+07	0.00	20990,									
1.920E+08	2.045E+08	1.15E+08	42.753	0.85	155093.94	1.25E+07	4.671	0.85	3501.849	1.025E+07	0.00	1.025E+07	0.00	1.025E+07	0.00	1.025E+07	0.00	123046,									
2.940E+08	3.065E+08	2.17E+08	80.836	0.85	154147.26	1.15E+08	42.753	0.85	32052.25	1.25E+07	4.671	0.85	3501.8487	1.025E+07	0.00	1.025E+07	0.00	93544,									
3.960E+08	4.085E+08	3.19E+08	118.918	0.85	153195.58	2.17E+08	80.836	0.85	60602.66	1.15E+08	42.753	0.85	32052.252	1.25E+07	4.671	0.85	3501.8487	1.025E+07	64042,								
4.980E+08	5.105E+08	4.21E+08	157.001	0.85	152243.9	3.19E+08	118.918	0.85	89153.06	2.17E+08	80.836	0.85	60602.655	1.15E+08	42.753	0.85	32052.252	1.25E+07	4.671	0.85	3501.8487	1.025E+07	34540,				
6.000E+08	6.125E+08	5.23E+08	195.083	0.85	151292.22	4.21E+08	157.001	0.85	117703.5	3.19E+08	118.918	0.85	89153.058	2.17E+08	80.836	0.85	60602.655	1.15E+08	42.753	0.85	32052.25193	1.25E+07	4.671	0.85	3501.8487	1.025E+07	5038,
<b>Maksimum</b>					213410.95				117703.5		89153.058		60602.655		32052.25193				3501.8487								
<b>Keputusan</b>					9.00E+07				6.00E+08		6.00E+08		6.00E+08		6.00E+08				6.00E+08								

Table 11 Simulation of August

## Tahap 8 (Agustus)

Inflow = 7.21 m<sup>3</sup>/dtk

Saktif, Debit PLTA, Efisiensi, Energi																										
Tamp.	Tamp. Awal	Tampungan Akhir																								
Awal	+ inflow	9000000		19200000			29400000		39600000			49800000		60000000												
9.000,E+07	1.093,E+08	1.93,E+07	7.210	0.85	218815.91										213410,											
1.920,E+08	2.113,E+08	1.21,E+08	45.292	0.85	247366.31	1.93,E+07	7.210	0.85	5404.962						213410,											
2.940,E+08	3.133,E+08	2.23,E+08	83.374	0.85	151658.83	1.21E+08	45.292	0.85	33955.37	1.93,E+07	7.210	0.85	5404.9622		89153,											
3.960,E+08	4.153,E+08	3.25,E+08	121.457	0.85	151658.83	2.23E+08	83.374	0.85	62505.77	1.21E+08	45.292	0.85	33955.365	1.93,E+07	7.210	0.85	5404.9622		60602,							
4.980,E+08	5.173,E+08	4.27,E+08	159.539	0.85	151658.83	3.25E+08	121.457	0.85	91056.17	2.23E+08	83.374	0.85	62505.769	1.21E+08	45.292	0.85	33955.365	1.93,E+07	7.210	0.85	5404.96215		32052,			
6.000,E+08	6.193,E+08	5.29,E+08	197.622	0.85	151658.83	4.27E+08	159.539	0.85	119806.6	3.25E+08	121.457	0.85	91056.172	2.23E+08	83.374	0.85	62505.769	1.21E+08	45.292	0.85	33955.36538	1.93,E+07	7.209	0.85	5404.9621	3501,
<b>Maksimum</b>					<b>247366.31</b>				<b>119806.6</b>		<b>91056.172</b>			<b>62505.769</b>			<b>33955.36538</b>			<b>5404.9621</b>						
<b>Keputusan</b>									<b>1.92E+08</b>					<b>6.00E+08</b>			<b>6.00E+08</b>			<b>6.00E+08</b>						

Sumber: Hasil Perhitungan

Table 12 Simulation of September

Tahan 9 (Sentember)

$$\text{Inflow} = 4.14 \text{ m}^3/\text{dt}$$

Sakitif, Debit PLTA, Efisiensi, Energi														
Tamp.	Tamp. Awal	Tampungan Akhir												
Awal	+ inflow	9000000		19200000		29400000		39600000		49800000		60000000		
9.000,E+07	1.007,E+08	1.07,E+07	4.138	0.85	250468.57	1.007,E+07	0.85	1.007,E+07	0.85	1.007,E+07	0.85	1.007,E+07	0.85	
1.920,E+08	2.027,E+08	1.13,E+08	43.490	0.85	152210.92	1.07E+07	4.138	0.85	3102.259	0.85	1.007,E+07	0.85	1.007,E+07	0.85
2.940,E+08	3.047,E+08	2.15,E+08	82.842	0.85	153162.8	1.13E+08	43.490	0.85	32604.34	1.07E+07	4.138	0.85	3102.2586	0.85
3.960,E+08	4.067,E+08	3.17,E+08	122.194	0.85	154114.28	2.15E+08	82.842	0.85	62106.43	1.13E+08	43.490	0.85	32604.342	1.07E+07
4.980,E+08	5.087,E+08	4.19,E+08	161.545	0.85	155065.96	3.17E+08	122.194	0.85	91608.51	2.15E+08	82.842	0.85	62106.425	1.13E+08
6.000,E+08	6.107,E+08	5.21,E+08	209.897	0.85	156017.64	4.19E+08	161.545	0.85	121110.6	3.17E+08	122.194	0.85	91608.503	2.15E+08
Maksimum			281468.57			12110.6		91608.53		62106.425		32604.34193		
Keputusan			9.00E+07			6.00E+08		6.00E+08		6.00E+08		6.00E+08		

Sumber: Hasil Perhitungan

Table 13 Simulation of October

Tahap 10 (Oktober)		Inflow =	2.97	$m^3/dtk$	Saktif, Debit PLTA, Efisiensi, Energi																	
Tamp.	Tamp. Awal	Tampungan Akhir																				
Awal	+ inflow	9000000		19200000			29400000			39600000			49800000			60000000						
9,000,E+07	9,796,E+07	7,96,E+06	2,972	0,85	252696,31											250468,57						
1,920,E+08	2,000,E+08	1,10,E+08	41,054	0,85	151888,73	7,96E+06	2,972	0,85	2227,734							121110,59						
2,940,E+08	3,020,E+08	2,12,E+08	79,136	0,85	150937,05	1,10E+08	41,054	0,85	30778,14	7,96E+06	2,972	0,85	2227,7336			91608,51						
3,960,E+08	4,040,E+08	3,14,E+08	117,219	0,85	149985,37	2,12E+08	79,136	0,85	59328,54	1,10E+08	41,054	0,85	30778,137	7,96E+06	2,972	0,85	2227,7336	62106,43				
4,980,E+08	5,060,E+08	4,16,E+08	155,301	0,85	149033,69	3,14E+08	117,219	0,85	87878,94	2,12E+08	79,136	0,85	59328,54	1,10E+08	41,054	0,85	30778,137	32604,34				
6,000,E+08	6,080,E+08	5,18,E+08	193,384	0,85	148082,01	4,16E+08	155,301	0,85	116429,3	3,14E+08	117,219	0,85	87878,949	2,12E+08	79,136	0,85	59328,54	30778,13678	2,972	0,85	2227,7336	3102,26
<b>Maksimum</b>		<b>252696,31</b>		<b>116429,3</b>			<b>87878,943</b>			<b>59328,54</b>			<b>30778,13678</b>			<b>2227,734</b>						
<b>Keputusan</b>		<b>9,00E+07</b>		<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>						

Sumber: Hasil Perhitungan

Table 14 Simulation of November

Tahap 11 (November)		Inflow =	3.76	$m^3/dtk$	Saktif, Debit PLTA, Efisiensi, Energi																
Tamp.	Tamp. Awal	Tampungan Akhir																			
Awal	+ inflow	9000000		19200000			29400000			39600000			49800000			60000000					
9,000,E+07	9,974,E+07	7,94,E+06	3,757	0,85	255512,93											252696,31					
1,920,E+08	2,017,E+08	1,12,E+08	43,109	0,85	148748,05	9,74E+06	3,757	0,85	2816,623							116429,35					
2,940,E+08	3,037,E+08	2,14,E+08	82,461	0,85	149699,73	1,12E+08	43,109	0,85	32318,71	9,74E+06	3,757	0,85	2816,6229			87878,94					
3,960,E+08	4,057,E+08	3,16,E+08	121,813	0,85	150651,41	2,14E+08	82,461	0,85	61820,79	1,12E+08	43,109	0,85	32318,708	9,74E+06	3,757	0,85	2816,6229	59328,54			
4,980,E+08	5,077,E+08	4,18,E+08	161,164	0,85	151603,09	3,16E+08	121,813	0,85	91322,87	2,14E+08	82,461	0,85	61820,79	1,12E+08	43,109	0,85	32318,70823	30778,14			
6,000,E+08	6,097,E+08	5,20,E+08	200,516	0,85	152554,77	4,18E+08	161,164	0,85	120825	3,16E+08	121,813	0,85	91322,873	2,14E+08	82,461	0,85	61820,79	3,757	0,85	2816,6229	2227,73
<b>Maksimum</b>		<b>255512,93</b>		<b>120825</b>			<b>91322,873</b>			<b>61820,79</b>			<b>32318,70823</b>			<b>2816,623</b>					
<b>Keputusan</b>		<b>9,00E+07</b>		<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>					

Sumber: Hasil Perhitungan

Table 15 Simulation of December

Tahap 12 (Desember)		Inflow =	5.66	$m^3/dtk$	Saktif, Debit PLTA, Efisiensi, Energi																					
Tamp.	Tamp. Awal	Tampungan Akhir																								
Awal	+ inflow	9000000		19200000			29400000			39600000			49800000			60000000										
9,000,E+07	1,052,E+08	1,52,E+07	5,658	0,85	259754,36											255512,93										
1,920,E+08	2,072,E+08	1,17,E+08	43,740	0,85	153616,79	1,52E+07	5,658	0,85	4241,428							120824,96										
2,940,E+08	3,092,E+08	2,19,E+08	81,822	0,85	152665,11	1,17E+08	43,740	0,85	32791,83	1,52E+07	5,658	0,85	4241,4278			91322,87										
3,960,E+08	4,112,E+08	3,21,E+08	119,905	0,85	151713,43	2,19E+08	81,822	0,85	61342,23	1,17E+08	43,740	0,85	32791,831	1,52E+07	5,658	0,85	4241,4278	61820,79								
4,980,E+08	5,132,E+08	4,23,E+08	157,987	0,85	150761,75	3,21E+08	119,905	0,85	89892,64	2,19E+08	81,822	0,85	61342,234	1,17E+08	43,740	0,85	32791,831	1,52E+07	5,658	0,85	4241,4278	32318,71				
6,000,E+08	6,152,E+08	5,25,E+08	196,070	0,85	149810,07	4,23E+08	157,987	0,85	118443	3,21E+08	119,905	0,85	89892,637	2,19E+08	81,822	0,85	61342,234	1,17E+08	43,740	0,85	32791,83098	1,52E+07	5,658	0,85	4241,4278	2816,62
<b>Maksimum</b>		<b>259754,36</b>		<b>118443</b>			<b>89892,637</b>			<b>61342,234</b>			<b>32791,83098</b>			<b>4241,4278</b>										
<b>Keputusan</b>		<b>9,00E+07</b>		<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>			<b>6,00E+08</b>										

Sumber: Hasil Perhitungan

Electrical energy from January to December at each initial level of reservoir was described as Table 16 below

Table 16 Electrical energy at each initial level of reservoir

No	Month	Initial level of reservoir (m <sup>3</sup> )					
		90000000	192000000	2940000000	3960000000	4980000000	6000000000
Electrical energy (kWh)							
1	Jani	148743,99	120193,5902	91643,1869	63092,7837	34542,38048	5991,97725
2	Feb	174247,7447	136646,3925	105037,017	73427,6425	41818,26749	10208,89249
3	Mar	185570,8387	125524,7069	96974,3036	68423,9004	39873,49718	11323,09395
4	Apr	195147,1316	127584,6263	98082,543	68580,4596	39078,37628	9576,29295
5	May	204870,7406	123925,2219	95374,8187	66824,4155	38274,01223	9723,609
6	Jun	209909,0995	123046,6922	93544,6089	64042,5255	34540,44218	5038,35885
7	Jul	213410,9482	117703,4616	89153,0584	60602,6552	32052,25193	3501,8487
8	Aug	247366,3136	119606,5751	91056,1718	62505,7686	33955,36538	5404,96215
9	Sep	250468,5722	121110,5919	91608,5086	62106,4253	32604,34193	3102,2586
10	Oct	252696,3057	116429,3465	87878,9432	59328,54	30778,13678	2227,73355
11	Nov	255512,9286	120824,9562	91322,8729	61820,7896	32318,70623	2816,6229
12	Dec	259754,3564	118443,0407	89892,6374	61342,2342	32791,83098	4241,42775
Max Energy		259754,3564	136646,3925	105037,017	73427,6425	41818,26749	11323,09395

## CONCLUSION

Based on analysis as above, it was concluded that maximum electrical energy was as follow:

- At initial level of 90,000,000 m<sup>3</sup> = 259,754.3564 kWh (December)
- At initial level of 19,200,000 m<sup>3</sup> = 136,646.3925 kWh (February)
- At initial level of 294,000,000 m<sup>3</sup> = 105,037.0170 kWh (February)
- At initial level of 396,000,000 m<sup>3</sup> = 73,427.6425 kWh (February)
- At initial level of 498,000,000 m<sup>3</sup> = 41,818.6279 kWh (February)
- At initial level of 600,000,000 m<sup>3</sup> = 11,323.09395 kWh (March)

## REFERENCES

- Shiklomadov, I.A.; Babkiu, V.I.; and Balouishukov, Zh.A. (2011) Water Resources, Their Use, and Water Availability in Russia: Current Estimates and Forecasts. *Journal of Water Resources* (38) no. 2, p 139-148
- Loaiciga, Hugo A (2005) On the Probability of Droughts: The Compound Renewal Model. *Journal of Water Resources Research*, Vol. 41, p 1-8
- Bhalla, R.S.; Pelkey, N.W.; and Prasad, K.V.D. (2011) Application of GIS for Evaluation and Design of Watershed Guidelines, *Journal of Water Resource Management*, 25: 113-140
- Arismunandar, A and Kuwahara, A (1991) *Teknik Tenaga Listrik, Jilid I*, cetakan keenam. PT Pradnya Paramita, Jakarta.
- Montarcih, Lily. 2010. *Hidrologi Praktis*. CV Lubuk Agung. Bandung
- Soetopo, Widandi & Montarcih, Lily. 2009. Manajemen Air Lanjut. CV Citra Malang. Indonesia. 111 pages